

LA-UR-18-27493

Approved for public release; distribution is unlimited.

Title: Fiber Optic Point Sensors for ESD Data Experiments

Author(s): Snyder, Hans R.

Intended for: NSR&D Proposal for submission to NA-50

Issued: 2018-08-07

Disclaimer:

Los Alamos National Laboratory, an affirmative action/equal opportunity employer, is operated by the Los Alamos National Security, LLC for the National Nuclear Security Administration of the U.S. Department of Energy under contract DE-AC52-06NA25396. By approving this article, the publisher recognizes that the U.S. Government retains nonexclusive, royalty-free license to publish or reproduce the published form of this contribution, or to allow others to do so, for U.S. Government purposes. Los Alamos National Laboratory requests that the publisher identify this article as work performed under the auspices of the U.S. Department of Energy. Los Alamos National Laboratory strongly supports academic freedom and a researcher's right to publish; as an institution, however, the Laboratory does not endorse the viewpoint of a publication or guarantee its technical correctness.

Fiber Optic Point Sensors for ESD Data Experiments

Abstract:

This NNSA NSR&D project will create an experimental data base of direct fiber optic point measurements of $E(\mathbf{x},t)$ and $B(\mathbf{x},t)$ from a ESD event. The data will be used to validate a physics based toolset being developed at LANL. The measurements can also be used to ascertain if a specific type of ESD event exceeds the NO FIRE limits for detonators.



Hans Snyder, NEN-2


August 8, 2018



Operated by Los Alamos National Security, LLC for the U.S. Department of Energy's NNSA

Simple Representative ESD Scenario

Maxwell's Equation Solver (MES) + Plasma Kinetic Arc Breakdown Solver




• Geometry: sphere above ground plane


- A sphere, characterized by conductivity σ and permittivity ε , is positioned at a fixed height z or dropped from a representative height above a ground plane.
- $20 \text{ kV/cm} \leq V \leq 30 \text{ kV/cm} \rightarrow Q$
- The MES provides the initial condition: $\rho(\mathbf{x}, t_0) \rightarrow \rho(\mathbf{x}, t)$
 - Generally yields $\mathbf{E}(\mathbf{x}, t)$, $\mathbf{B}(\mathbf{x}, t)$, $\rho(\mathbf{x}, t)$ and $\mathbf{J}(\mathbf{x}, t)$
 - These field quantities are required to simulate the arc formation, and the discharge from the sphere, through the arc, and into the victim load and ground plane.

• Discharge Arc: $R_{arc}(t)$ is the required unknown

- **High resistance** → Initial avalanche (streamer)
- **Discharge path formation:** $\sigma_{arc}(t)$ strongly depends on % ionization
- **Basic plasma effects:**
 - **Energy:** field heating, inter-species transfer, conduction
 - **Particles:** ionization, recombination, attachment, diffusion
 - **Flow:** channel expansion, shockwave propagation
- **Relaxation:** recombination + cooling → **High resistance**



Threshold Arc: $R_{arc}(t) \gg 1 \Omega$



Overdriven Arc: $R_{arc}(t) \ll 1 \Omega$



Project Outline

Problem and Solution:

The ESD Issue: Because costly and unrealistic conservative assumptions about ESD events drive mitigations for safety operations, the fundamental scientific work of creating and implementing a credible physics-based toolset to address ESD scenarios does not exist.

Solution Product: Create an experimentally validated physics-based toolset that can be utilized to simulate ESD discharge events in air, and thus support a defensible position to implement a less conservative NES weapon response.

Strategy:

- Use First principles approach to solve the problem
- Use simple and straight forward representative ESD scenario
- Use base models + toolset + data set
- Use asymptotic Non-Linear Resistance models
- Use data to support non-linear modeling
- Use toolset and database to support position in NES weapon response.

Fiber Optic Point Sensors for Generating Validation Datasets

Experiment Basics and Plan

- LANL currently has plasma science efforts to develop fiber optic sensors to measure magnetic field and electric field with high spatial resolution and temporal resolution
- Magnetic field measurement based on the Faraday Effect
- Electric field measurement based on the Kerr Effect and Pockel Effect
- Diagnostic can be used to measure electric field and magnetic field for various ESD experiments
- Experiment data can be used to validate physics based toolset
- Experiment data can also be used to ascertain if an ESD event, *under realistic conditions*, could transfer energy in such a way that exceeds the NO FIRE limits for a given detonator.


Fiber Optic Point Sensors for Generating Validation Datasets

Experiment Basics and Plan

- LANL currently has plasma science efforts to develop fiber optic sensors to measure magnetic field and electric field with high spatial resolution and temporal resolution
- Magnetic field measurement based on the Faraday Effect
- Electric field measurement based on the Kerr Effect and Pockels Effect
- Diagnostic can be used to measure electric field and magnetic field for various ESD experiments
- Experiment data can be used to validate physics based toolset
- Experiment data can also be used to ascertain if an ESD event, *under realistic conditions*, can transfer energy in such a way that exceeds the NO FIRE limits for a given detonator.

Fiber Magneto-Optic Sensor


- Magnetic Field Optical Fiber Measurement Based on Faraday Rotation
- Degree of rotation θ of the plane of polarization is dependent on the strength of the magnetic field
- Sensitivity of diagnostic is dependent on the wavelength of the light and material properties of the fiber



http://en.wikipedia.org/wiki/Faraday_effect

Fiber Electro-Optic Sensor

- Pockels Effect is a linear electro-optic changes that creates birefringence in a optical material from a applied electric field. Birefringence is the an optical phenomena where the refractive index depends on the polarization of light.
- Kerr Effect is a quadratic electro-optic effect.
- Change in polarization vector depends on the strength of the electric field
- Sensitivity of diagnostic depends on material properties of the fiber



https://en.wikipedia.org/wiki/Pockels_effect


Fiber Sensor Experiment Tasks

- Determine most effective materials for magneto-optic and electro-optic sensor
- Custom fabricate fiber cable using selected materials for each type of sensor
- Determine if sensitivity of sensor is sufficient to generate relevant data
- Determine if sensor can be configured in a manner to be of practical use for ESD application.
- Compare experimental data to toolset calculations



Basic Test Steps

- Test various size metallic spheres
- Charge sphere to various voltage
- Initiate ESD event
- Measure electric field and magnetic field at a point of interest
- Calculate total energy transfer over ESD event



Basic Experimental Test Set-Up